



Approval of the Trademark Trevira CS Bioactive®

Silent Gliss
Fabrics & Components GmbH
Rheinauenstrasse 8
79415 Bad Bellingen
Germany

Application No.:	230015.1
Date of issue:	15.02.2023
Valid until:	15.02.2028
Article name:	COLORAMA 1 BIOACTIVE
End use:	Curtains
Square weight (g/m²):	135
According to customer specification	
Composition of the raw materials:	100% Polyester
Composition of the fabric:	50% Trevira CS bioactive 50% Trevira CS

The article COLORAMA 1 BIOACTIVE has been tested under the Trevira trademark application no. 230015 and is granted approval for the trademark Trevira CS Bioactive® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article has been tested according to the modified JIS L 1902 Test: Testing Antibacterial Activity and Efficacy on Textile Products and meets the requirements for the trademark Trevira CS Bioactive.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Trevira GmbH
(This document is valid without signature.)

Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany
E-Mail: trademark.service@trevira.com